

DESCRIPTION

PRODUCT COVERED:

USR Component - Capacitors, Construction Only, Cat. No. CBB61 Series.

ELECTRICAL RATINGS:

Cat. No.	Input		Capacitance, uF
	Voltage, V ac	Frequency, Hz	
CBB61 Series	250-500	50 / 60	1 - 12

ENGINEERING CONSIDERATIONS (NOT FOR FIELD REPRESENTATIVE'S USE):

Use - For use only in complete equipment where the acceptability of the combination is determined by Underwriters Laboratories Inc.

USR indicates investigation to UL 810, standard for Capacitors.

Conditions of Acceptability - When installed in the end-use equipment, consideration shall be given to the following.

1. A minimum electrical air spacing shall be required in the end-use application when measured in a direction perpendicular to the cover (mounting surface of the terminals).

Total Spacings

Maximum Voltage

3/8 in. (9.5 mm) (or end-use application spacings)

500

2. The open circuit voltage of the capacitor terminals shall not exceed 500 V ac.
3. This Report covers only the general construction per the requirements in UL 810, Fifth Edition, Part 1, features on the capacitors and no evaluation of the performance during short-circuit conditions has been conducted. This should be determined for the end-use application.
4. The suitability of the mounting means shall be evaluated in the end-use application.